



#### NOTES:

1. A TEMPORARY JUMPER CONNECTION IS REQUIRED AT ALL CONNECTIONS BETWEEN EXISTING ACTIVE POTABLE AND REUSE WATER MAINS AND PROPOSED WATER AND REUSE MAIN IMPROVEMENTS
2. THE DETAIL ABOVE IS TO BE USED FOR PIGGING, FILLING, FLUSHING, AND PULLING SAMPLES FROM NEW WATER MAINS. UNTIL SUCH TIME AS FDEP HAS CLEARED THE POTABLE WATER MAIN FOR USE OR TOHO HAS CLEARED THE POTABLE OR REUSE MAIN FOR USE IF NO FDEP PERMIT IS REQUIRED, THE JUMPER MUST REMAIN ON AND THE VALVE BETWEEN THE OLD AND NEW SYSTEMS MUST REMAIN CLOSED
3. THE DEVELOPER AND/OR CONTRACTOR WILL PURCHASE THE TEMPORARY JUMPER ASSEMBLY FROM TOHO. ONLY JUMPERS PURCHASED DIRECTLY THRU TOHO ARE ALLOWED
4. THE INSTALLATION AND MAINTENANCE OF THE TEMPORARY JUMPER IS THE RESPONSIBILITY OF THE DEVELOPER AND/OR THE CONTRACTOR
5. 2" TAPS AND SERVICES UPSTREAM AND DOWNSTREAM OF THE JUMPER ASSEMBLY SHALL BE PER DETAIL TOHO-01
6. GALVANIZED PIPE AND/OR FITTINGS ARE NOT ALLOWED
7. ABANDONED JUMPER CONNECTIONS MUST BE INCLUDED ON THE FINAL RECORD DRAWINGS