



NOTES:

1. ALL FITTINGS INCLUDING BUT NOT LIMITED TO THE STRAINER, METER, CHECK VALVE, TEE, ETC. SHALL BE THE RESPONSIBILITY OF THE DEVELOPER AND/OR CONTRACTOR TO PROVIDE AND INSTALL
2. GALVANIZED PIPE IS NOT ALLOWED
3. PROTECTIVE BOLLARD(S) MAY BE REQUIRED AT THE DISCRETION OF TOHO
4. MAINTAIN A MINIMUM 3' CLEARANCE AROUND ALL SIDES OF THE ASSEMBLY FREE OF PLANTINGS, STRUCTURES, OTHER UTILITIES, ETC.
5. IF CHEMICAL INJECTION IS USED, THE CHECK VALVE SHALL BE REPLACED WITH A REDUCED PRESSURE ZONE (RPZ) BACKFLOW DEVICE
6. IF JUMPED TO POTABLE, A REDUCED PRESSURE ZONE (RPZ) BACKFLOW DEVICE WILL BE REQUIRED WHERE A CHECK VALVE IS SHOWN IN THE ABOVE DETAIL
7. IF JUMPED TO POTABLE, ABOVE GROUND PIPING UP TO AN INCLUDING THE METER SHALL BE PAINTED BLUE, DOWNSTREAM OF THE METER SHALL BE PURPLE