



SERVICE NOTES:

1. CORP STOPS SHALL BE NO LEAD BRASS. INLET SHALL BE MATCHED TO TAPPING SADDLE AND OUTLET SHALL BE FIP THREAD AND PACK JOINT ADAPTER W/ CLAMP SCREW RETAINER
2. CURB STOPS SHALL BE LOCKING TYPE, STRAIGHT BALL VALVE, NO LEAD BRASS WITH SWIVEL METER NUT CONNECTION.
3. SERVICE WYES SHALL BE NO LEAD BRASS PACK JOINT W/ CLAMP SCREW RETAINER
4. METER COUPLINGS SHALL NOT BE USED
5. SERVICE LINE SHALL BE CONTINUOUS, NO FITTINGS ARE PERMITTED ON THE POLY LINE BETWEEN THE CORP STOP AND THE CURB STOP OR BETWEEN THE CORP STOP AND THE WYE
6. NO CURB STOPS SHALL BE INSTALLED UNDER AN IMPERVIOUS SURFACE OR STRUCTURE
7. SERVICE TAPS SHALL BE A MINIMUM OF 18" FROM JOINTS, FITTINGS, OR OTHER TAPS ON THE MAIN.
8. SERVICE TUBING SHALL BE POLYETHYLENE DR9, 200PSI. BLUE FOR POTABLE, PURPLE FOR REUSE
9. PLACE APPROVED 3M MARKER TAPE TO THE CURB STOP(S) TIED INTO THE MARKER TAPE AT THE MAIN
10. SERVICE LINES SHALL BE MARKED IN THE CURB OR SIDEWALK IMMEDIATELY ADJACENT TO PARKING SPACES WITH A 3" TALL "W" FOR WATER OR A 3" TALL "R" FOR REUSE
11. THIS DETAIL IS INTENDED FOR 3/4" AND 1" METERS ONLY. FOR 1.5" OR 2" METERS REFER TO TOHO-02
12. THIS DETAIL IS INTENDED FOR SINGLE OR DOUBLE SERVICE CONNECTIONS ONLY. FOR GROUPS OF 3 -8 METERS REFER TO TOHO-03.0, TOHO-03.1, AND TOHO-03.2

METER AND METER BOX PLACEMENT NOTES

1. METERS 3/4" TO 1" ARE PAID FOR BY THE DEVELOPER AND INSTALLED BY TOHO
2. METER BOX(ES), SERVICE LINES, AND ALL ASSOCIATED APPURTENANCES SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR OR DEVELOPER
3. TOHO PROVIDES APPROVED IN-GROUND BACKFLOW DEVICES ON ALL 3/4" AND 1" METERS
4. CURB STOP SHALL BE INSTALLED WITH THE OPERATING NUT FACING UP
5. PLACE FILTER FABRIC UNDER THE METER BOX EXTENDING 1' IN ALL DIRECTIONS. WRAP THE EXCESS AROUND THE SIDES OF THE BOX AND TAPE TIGHT TO THE BOX
6. NO PLANTINGS, STRUCTURES, OR OTHER UTILITIES, INCLUDING BUT NOT LIMITED TO TELECOM PEDESTALS, ELECTRICAL TRANSFORMERS OR POLES, ETC. SHALL BE INSTALLED WITHIN 36" OF ANY SIDE OF THE METER BOX
7. BUILDER SHALL MAKE FINAL HORIZONTAL AND VERTICAL ADJUSTMENTS TO METER ASSEMBLY AND BOX
 - 7.1. METER SHALL BE APPROXIMATELY 7" BELOW FINISHED GRADE AND CENTERED IN THE BOX
 - 7.2. SINGLE SERVICE BOX SHALL BE PERPENDICULAR TO THE CURB OR SIDEWALK
 - 7.3. DOUBLE SERVICE BOXES SHALL BE PARALLEL TO THE CURB OR SIDEWALK
 - 7.4. TOP OF METER BOX SHALL BE FLUSH WITH FINISH GRADE
8. METER BOX LID SHALL BE SOLID PLASTIC WITH NO METAL ACCESS DOOR, BLACK FOR WATER, PURPLE FOR REUSE