



1. THIS DETAIL APPLIES TO BOTH ENTRY AND EXIT PORTS
2. CRUSHED STONE BEDDING 6" MINIMUM BELOW VALVE AND VAULT SHALL BE COVERED WITH FILTER FABRIC
3. NO PLANTINGS, STRUCTURES, OR OTHER UTILITIES INCLUDING BUT NOT LIMITED TO TELECOM PEDESTALS, ELECTRICAL TRANSFORMERS OR POLES, ETC. SHALL BE INSTALLED WITHIN 36" OF ANY SIDE OF THE GATE VAVLES OR VAULT