

SDC Calculation Procedures

• Meters $\leq 2''$

- **Developers or Engineering Representatives**
 - *Calculate and submit size and number of potable water meters*
- **Assets & Infrastructure**
 - *Group reviews and approves (or requests revisions)*
- **Financial Services**
 - *Applied charges based on meter size, per Res. 2022-12 rate schedule*

• Meters $> 2''$

- **Developers or Engineering Representatives**
 - *Calculate and submit water and wastewater demands*
- **Assets & Infrastructure**
 - *Group reviews and approves (or requests revisions)*
- **Financial Services**
 - *Applied Res. 2022-12 cost per gallon from rate schedule to the estimated water and wastewater demands*

Acceptable Flow Estimation Procedures (meters $> 2''$ only)

State Flow Guidelines

Use Table I Section 62-6.008 of the State of Florida Department of Health in [Exhibit A](#) .
Assume potable water and wastewater flows are equal

Engineering Assessment

Submit detailed engineering assessment of flows based upon anticipated equipment and use data

Comparative Assessment

Provide data from **two to three similar developments**, minimum 1-year of flow use data per development

For more details, see [Exhibit A](#)