

Water/Wastewater Levels of Service Assumptions

Water Source	GPD/ERU	Peak Day Factors	Total GPD
Avg. Daily Flow (potable water)	200 gpd	X Peak Day Factor of 1.2 =	240 gpd
Supplemental Water Use (irrigation)	266 gpd		
Water from Reclaimed Water Supply	- 184 gpd		
	= 82 gpd	X Peak Day Factor of 2.0 =	+ 164 gpd
Water Total gpd per Equivalent Residential Unit (ERU)			= 404 gpd*
Wastewater per ERU (unchanged)	184 gpd	X Peak Factor of 1.5 =	276 gpd

* Rounded to 400 gpd (see Res. No.2022-12)