



## **Items commonly missed during Meter Installation**

**Toho only installs meters for service lines 2" and under.**

- Meter boxes set and installed at grade level.
- Sunken panels will not be accepted.
- Meter boxes must be free of cracks and or breaks.
- Curb Stops must be centered and facing up.
- Line must be in service and water flowing.
- Meter boxes must be identified/located at road with corresponding address.
- For a 2-inch service line, there must be a minimum of 18 inches between each flange.

Missed items may result in a failed installation. Failed installations may result in additional fees and lead time.