



COVER BOLTDOWN DETAIL

- MATERIAL: FIBERGLASS REINFORCED POLYMER CONCRETE & FIBERGLASS REINFORCED POLYMER

NOTES:

- THIS DETAIL IS INTENDED FOR GROUPS OF 5 TO 6 - 3/4" METERS.
- SEE TYPICAL RESIDENTIAL WATER SERVICE DETAIL TOHO-01 FOR ADDITIONAL REQUIREMENTS
- CURB STOP SUPPLIED INSIDE THE VAULT SHALL BE PLACED ON THE DOWNSTREAM SIDE OF THE INTERIOR MANIFOLD
- CONTRACTOR SHALL BE RESPONSIBLE FOR ENSURING METER VAULTS ARE PROPERLY ORIENTED PER THE TOHO APPROVED DRAWINGS AND DETAILS
- VAULT SHALL BE SET TO SOD GRADE
- ALL PIPE AND FITTINGS INSIDE THE VAULT SHALL BE NO LEAD BRASS
- METER VAULTS MUST BE ORDERED WITH THE APPROPRIATE METER SIZE(S) SPECIFIED. NO ALTERATIONS TO THE INTERIOR MANIFOLD ARE PERMITTED AFTER DELIVERY
- CURB STOP ON 2" WATER SERVICE SHALL BE INSTALLED WITH THE OPERATING NUT FACING UP
- PLACE #57 STONE A MINIMUM OF 6" DEEP EXTENDING 1' BEYOND ALL EDGES OF THE VAULT. PLACE FILTER FABRIC UNDER THE VAULT ABOVE THE #57 STONE EXTENDING 1' BEYOND ALL EDGES.
- PLACE APPROVED 3M MARKER TAPE TO THE CURB STOP AND TIED INTO THE TAPE AT THE MAIN