



NOTES:

1. THIS DETAIL APPLIES TO BOTH ENTRY AND EXIT PORTS.
2. THIS DETAIL DOES NOT APPLY TO LIFT STATION PIG PORT / EMERGENCY BYPASS DISCHARGE PORT.
3. CRUSHED STONE BEDDING 6" MINIMUM BELOW VALVE AND VAULT SHALL BE COVERED WITH FILTER FABRIC.
4. NO PLANTINGS, STRUCTURES, OR OTHER UTILITIES INCLUDING BUT NOT LIMITED TO TELECOM PEDESTALS, ELECTRICAL TRANSFORMERS OR POLES, ETC. SHALL BE INSTALLED WITHIN 36" OF ANY SIDE OF THE GATE VAVLES OR VAULT.



EFFECTIVE DATE:	04/01/2025
BOARD APPROVED DATE:	01/22/2025
PREVIOUS VERSION:	2022
DRAWN BY:	MP
REVISED BY:	DT

PIG PORT

DRAWING NUMBER

33