



2" TAPPED PLUG AND 2" GATE VALVE FOR STUB-OUT INSTALLATIONS
2" PACK JOINT X FIP TEE AND 2" GATE VALVE FOR CUL-DE-SAC INSTALLATION

NOTES:

1. NO PLANTINGS, STRUCTURES, OR OTHER UTILITIES, INCLUDING BUT NOT LIMITED TO TELECOM PEDESTALS, ELECTRICAL TRANSFORMERS OR POLES, ETC. SHALL BE INSTALLED WITHIN 36" OF ANY SIDE OF THE FLUSHING DEVICE OR METER BOX.
2. BOLLARDS SHALL BE REQUIRED ON A CASE-BY-CASE BASIS AS DIRECTED BY TOHO.
3. FLUSHING DEVICES SHALL BE SET BEHIND THE RIGHT-OF-WAY LINE AND CENTERED ON A LOT LINE.
4. ALL SOD WITHIN 20 LINEAR FEET IN ALL DIRECTIONS MUST BE INSTALLED BEFORE THE FLUSHING DEVICE CAN BE ACTIVATED.
5. TOHO REQUIRES BLUETOOTH CONTROLLERS FOR ALL FLUSHING DEVICES.



EFFECTIVE DATE:	04/01/2025
BOARD APPROVED DATE:	01/22/2025
PREVIOUS VERSION:	2022
DRAWN BY:	MP
REVISED BY:	DT

AUTOMATIC FLUSHING DEVICE

DRAWING NUMBER
24