



NOTES:

1. BLOWOFF SHALL TERMINATE WITH A 2" LOCKABLE CURB STOP IN A PLASTIC DOUBLE METER BOX.
2. BOX SHALL BE SET PER DETAILS TOHO-01, TOHO-01.1, & TOHO-0.2.
3. MAIN SHALL BE PIGGED PRIOR TO INSTALLING BLOWOFF.
4. ALL SADDLES, STOPS, & FITTINGS SHALL BE NO LEAD BRASS PACK JOINT W/ CLAMP SCREW RETAINER. NO GALVANIZED PIPE OR FITTINGS ALLOWED.



EFFECTIVE DATE:	04/01/2025
BOARD APPROVED DATE:	01/22/2025
PREVIOUS VERSION:	2022
DRAWN BY:	MP
REVISED BY:	DT

BLOW-OFF

DRAWING NUMBER

25