



NOTES:

- #57 STONE BEDDING SHALL BE REQUIRED A MINIMUM DEPTH OF 6" BELOW ALL VALVES. PLACE FILTER FABRIC OVER STONE PRIOR TO SETTING VALVE.
- NO PLANTINGS, STRUCTURES, OR OTHER UTILITIES, INCLUDING BUT NOT LIMITED TO TELECOM PEDESTALS, ELECTRICAL TRANSFORMERS OR POLES, ETC. SHALL BE INSTALLED WITHIN 36" OF ANY SIDE OF ANY VALVE.
- OPERATING NUT SHALL BE BOLTED, SHEER PINS ARE NOT PERMITTED.
- WHERE THE VALVE OPERATING NUT MUST BE SET DEEPER THAN 24", A BOLT ON VALVE NUT RISER SHALL BE REQUIRED.
- TWO PIECE FULL DEPTH CAST IRON SCREW TYPE ADJUSTABLE VALVE BOXES ARE REQUIRED. PVC, DIP, OR CI VALVE BOX EXTENSIONS ARE NOT PERMITTED.
- LOCATOR WIRE ACCESS FOR DIRECTIONAL BORE OR JACK AND BORE APPLICATIONS:
 - IN UNPAVED AREAS USE 2" SCH80 PVC, FEMALE ADAPTER COUPLING AND 2" BRASS PLUG W/ RECESSED NUT SET IN THE VALVE PAD.
 - IN PAVED AREAS TERMINATE THE LOCATE WIRE INSIDE THE TOP PORTION OF THE VALVE BOX.
 - PROVIDE A MINIMUM OF 12" OF EXTRA WIRE ABOVE FINISHED GRADE.
- PRIVATELY MAINTAINED SYSTEMS SHALL HAVE 'PRIVATE' STAMPED ON THE BRONZE DISC.
- DEDICATED FIRE LINES SHALL HAVE 'FIRE' STAMPED ON THE BRONZE DISC AND THE VALVE COVER SHALL BE PAINTED RED.



EFFECTIVE DATE:	04/01/2025
BOARD APPROVED DATE:	01/22/2025
PREVIOUS VERSION:	2022
DRAWN BY:	MP
REVISED BY:	DT

VALVE AND BOX

DRAWING NUMBER

17.0