



NOTES:

1. THIS DETAIL APPLIES ONLY WHEN THE WATER MAIN CANNOT BE LOOPED AND WILL ONLY BE ALLOWED AT THE DISCRETION OF TOHO.
2. AN AUTOMATIC FLUSHING DEVICE (AFD) WILL BE INSTALLED BY THE CONTRACTOR AND/OR DEVELOPER ON THE POTABLE WATER LOOP ONLY.
3. THE AFD SHALL BE SET BEHIND THE RIGHT-OF-WAY LINE AND ON A SIDE PROPERTY LINE.
4. PLACE APPROVED 3M MARKER TAPE OVER THE 2" MAIN. MARKER TAPE SHALL TIE INTO THE MARKER TAPE AT THE GATE VALVE AND TERMINATE AT ALL CURB STOPS ALONG THE LOOP, INCLUDING TO THE AFD SERVICE.
5. THE MAXIMUM NUMBER OF $\frac{3}{4}$ " METERS ON A 2" LOOP SHALL BE 8.
6. ALL TEES, STOPS, AND WYES DOWNSTREAM OF THE TEE W/ 2" TAPPED PLUGS SHALL BE NO LEAD BRASS PACK JOINT TYPE W/ CLAMP SCREW



EFFECTIVE DATE:	04/01/2025
BOARD APPROVED DATE:	01/22/2025
PREVIOUS VERSION:	2022
DRAWN BY:	MP
REVISED BY:	DT

TYPICAL CUL-DE-SAC PIPING

DRAWING NUMBER

04